

LLOYD'S REGISTER TYPE APPROVAL

Issue by: Trieste Technical Support Office

Issued to: F.lli Giacomello S.r.l.

For: Electromagnetic level indicators

LV/M-76/127/254-S1

The undernoted documents have been reviewed for compliance with the requirements of the Lloyd's Register Type Approval System Procedure TA14 Version 03 (July 2019) and this Design Appraisal Document forms part of the Certificate LR2011166TA.

APPROVAL DOCUMENTATION

Type Approval Application Checklist	26/06/2020
Form 2502TA – Request for Marine Service – Ref. No. TAC – 2019/134a / SQ155346	03/08/2020
Form PQA – Production Quality Assessment Form, F.lli Giacomello S.r.l. – Rho (MI)	28/04/2020
TÜV NORD ISO 9001: 2015 Certificate n° 44 100 20410002	25/11/2019
Instructions for Use and Installation Mod. LV/M-76-S1 LV/M-127-S1 LV/M-254-S1 Cod. R29-11 Rev. 0	07/2019

TEST REPORTS

InLAB S.r.l. Test Report No. 1910240950 - IEC 60730-1:2010	02/10/2019
InLAB S.r.l. Test Report No. 1910240847 - IEC 60730-2-15:2008	22/10/2019
REI Lab. S.r.l. Test Report No. RD0807191374 - EN 55011 :2009+A1 :2010	30/07/2019

M. Crucil

Senior Specialist – Electrotechnical System

Trieste Technical Support Office

Lloyd's Register EMEA



Supplementary Type Approval Terms and Conditions

Type Approval certifies that a representative sample of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein. It does not mean or imply approval for any other use, nor approval of any product(s) designed or manufactured otherwise than in strict conformity with the said representative sample.

Type Approval is based on the understanding that the manufacturer's recommendations and instructions and any relevant requirements of the Rules and Regulations are complied with.

Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations.

Lloyd's Register EMEA reserves the right to cancel or withdraw this Type Approval Certificate in accordance with the Lloyd's Register Type Approval System Procedure.

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer	F.Ili Giacomello Srl.
Address	Via Magenta, 77 Cap 15/A, Rho (MI), 20017, Italy
Type	Switches - Level
Description	Electromagnetic level indicator
Trade Name	LV/M-76/127/254-S1
Application	Marine, Offshore and Industrial
Specified Standard	<ul style="list-style-type: none">• Manufacturer's Specification• IEC 60730-1:2010• IEC 60730-2-15:2008• EN 55011:2009+A1:2010
Ratings	40 W/VA, 2 A @ 230 VDC/VAC Rated pressure: 5bar

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.



Maurizio Crucil

TTSO Senior Specialist to Lloyd's Register
EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United
Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Type Approval Certificate

The Design Appraisal Document No. LR2011166DA and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United
Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

